



Certificate number: 2106747

Date issued 18th June 2021

Date expired 17th June 2026 Original/Amendment *Amendment*

Kiwa UK Regulation 4 (KUKreg4) Approval

ATS3 – Without Production Surveillance

Issued by Kiwa Watertec (UK)

Evaluation Guideline: Kiwa UK – EG004
Reference Standards: Regulators Specification
Model Designations: see Appendix

Manufacturer: Dorot Management Control Valves Ltd.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied on to comply with the above Evaluation Guideline and Standards, and can be marked with the KUKreg4mark.

The intended use of this certificate is for compliance with Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales; 2009 Northern Ireland and 2014 Byelaws Scotland

This certificate has been issued in accordance with the Kiwa regulations for product certification

Signed on behalf of Kiwa Watertec

David Jay,
Business Unit Manager – Authorised Signatory
Kiwa Watertec

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate issued to:
Dorot Management Control Valves Ltd
Kibbutz Dorot
791500
DN Hof Ashkelon
ISRAEL



390170301

UK Approval Certificate (page 2 of 2)

Appendix to Certificate 2106747

The following products are covered by this certificate -

PRODUCT DESCRIPTION Series '500' range of pilot operated pressure reducing valves with ductile iron bodies (blue polyester or epoxy coating) and EPDM diaphragm. ATS3 – Without Production Surveillance.
MODEL(S) Series '500'
SIZE: Series 500 - 2" - 8" flanged inlet/outlet.
SCOPE: Manufacturer recommended maximum working pressure 25 Bar & maximum operating temperature: Cold water use only. Pressure reducing facility range = 1-16 bar. Hygienic Purposes: Non-metallic materials suitable for continuous use with cold water only. Above ground use only.
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
MARKING Dorot logo, date, STD, size & pressure rating on data plate on body.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes