



Certificate of Compliance

This certificate is issued for the following:

DELUGE AND PREACTION SPRINKLER SYSTEMS

Aquestia 68F Models DE\EL-MR, DE\RC-MR, DE\PTMR, DE\EL\PTMR, DE\RC-LC, DE\EL-MR

WITH PRESSURE REDUCING CONTROL

Aquestia 68F Model DE\RCL\PRF, DE\PTMR\PRF, DE\EL\PTMR\PRF

Sizes: 2, 2.5, 3, 4, 6, 8 inch NPS

Prepared for:

OCV Control Valves
7400 E 42nd Place, Tulsa, Oklahoma 74145
United States of America

Approval Standards: FM 1011, 1012, 1013 (Dec 2020), 1020 (dated Dec 2020), 1362 (dated Jan 2020)

Approval Identification: PR462587

Approval Granted: 1 October 2025

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



A handwritten signature in black ink, reading 'David B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062

